



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası KOCAELİ/TÜRKİYE
www.effectis.com

TEST CERTIFICATE

Certificate No: EEA – 2000 – 0009

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on **20.01.2020** in accordance with EN 12101-3:2015 standard for the product as described below:

“T-FWA 1400” SMOKE AND HEAT EXHAUST TUNNEL FAN

Motor downstream direction

FIRE RESISTANCE CLASSIFICATION	
F ₄₀₀	120

Placed on the market by

Atlasium Mob. İthalat İhracat San. Tic. Ltd. Sti.
Minareli Çavuş Organize Sanayi Bölgesi 202. Sokak No:19, Nilüfer, BURSA, TURKEY

And Produced In the Factory

Atlasium Mob. İthalat İhracat San. Tic. Ltd. Sti.
Minareli Çavuş Organize Sanayi Bölgesi 202. Sokak No:19, Nilüfer, BURSA, TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **RFTR20011**.

This certificate is initially valid until **22nd January 2021** providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
22.01.2020

